

Energy performance certificate (EPC)

84 Neale Street
Clowne
CHESTERFIELD
S43 4SD

Energy rating

D

Valid until:

4 November 2034

Certificate number:

4320-0095-0047-5098-1483

Property type

Detached house

Total floor area

134 square metres

Rules on letting this property

Properties can be let if they have an energy rating from A to E.

You can read [guidance for landlords on the regulations and exemptions](https://www.gov.uk/guidance/domestic-private-rented-property-minimum-energy-efficiency-standard-landlord-guidance) (<https://www.gov.uk/guidance/domestic-private-rented-property-minimum-energy-efficiency-standard-landlord-guidance>).

<https://find-energy-certificate.service.gov.uk/energy-certificate/4320-0095-0047-5098-1483?print=true>

1/5

Energy rating and score

This property's energy rating is D. It has the potential to be B.

[See how to improve this property's energy efficiency.](#)

Score	Energy rating	Current	Potential
92+	A		
81-91	B		83 B
69-80	C		
55-68	D	58 D	
39-54	E		
21-38	F		
1-20	G		

The graph shows this property's current and potential energy rating.

For properties in England and Wales:
the average energy rating is D
the average energy score is 60

Properties get a rating from A (best) to G (worst) and a score. The better the rating and score, the lower your energy bills are likely to be.

Breakdown of property's energy performance

Features in this property

Features get a rating from very good to very poor, based on how energy efficient they are. Ratings are not based on how well features work or their condition.

Assumed ratings are based on the property's age and type. They are used for features the assessor could not inspect.

Feature	Description	Rating
Wall	Solid brick, as built, no insulation (assumed)	Very poor
Roof	Pitched, 300 mm loft insulation	Very good
Window	Fully double glazed	Average
Main heating	Boiler and radiators, mains gas	Good
Main heating control	Programmer, room thermostat and TRVs	Good
Hot water	From main system	Good
Lighting	Low energy lighting in all fixed outlets	Very good
Floor	Solid, no insulation (assumed)	N/A
Secondary heating	Room heaters, mains gas	N/A

Primary energy use

The primary energy use for this property per year is 300 kilowatt hours per square metre (kWh/m2).

How this affects your energy bills

An average household would need to spend **£3,549 per year on heating, hot water and lighting** in this property. These costs usually make up the majority of your energy bills.

You could **save £1,604 per year** if you complete the suggested steps for improving this property's energy rating.

This is **based on average costs in 2024** when this EPC was created. People living at the property may use different amounts of energy for heating, hot water and lighting.

Heating this property

Estimated energy needed in this property is:

- 23,216 kWh per year for heating
- 2,307 kWh per year for hot water

Impact on the environment

This property's environmental impact rating is E.
It has the potential to be C.

Properties get a rating from A (best) to G (worst)
on how much carbon dioxide (CO2) they
produce each year.

Carbon emissions

An average household produces 6 tonnes of CO2

This property produces 7.1 tonnes of CO2

This property's potential production 2.8 tonnes of CO2

You could improve this property's CO2 emissions
by making the suggested changes. This will help
to protect the environment.

These ratings are based on assumptions about
average occupancy and energy use. People
living at the property may use different amounts
of energy.

Steps you could take to save energy

Step	Typical installation cost	Typical yearly saving
1. Internal or external wall insulation	£4,000 - £14,000	£1,297
2. Floor insulation (solid floor)	£4,000 - £6,000	£217
3. Solar water heating	£4,000 - £6,000	£90
4. Solar photovoltaic panels	£3,500 - £5,500	£618

Help paying for energy improvements

You might be able to get a grant from the [Boiler Upgrade Scheme \(https://www.gov.uk/apply-boiler-upgrade-scheme\)](https://www.gov.uk/apply-boiler-upgrade-scheme). This will help you buy a more efficient, low carbon heating system for this property.

More ways to save energy

Find ways to save energy in your home by visiting www.gov.uk/improve-energy-efficiency

Who to contact about this certificate

Contacting the assessor

If you're unhappy about your property's energy assessment or certificate, you can complain to the assessor who created it.

Assessor's name	Andrew Precious
Telephone	07791161778
Email	admin@cp-ps.co.uk

Contacting the accreditation scheme

If you're still unhappy after contacting the assessor, you should contact the assessor's accreditation scheme.

Accreditation scheme	Quidos Limited
Assessor's ID	QUID209264
Telephone	01225 667 570
Email	info@quidos.co.uk

About this assessment

Assessor's declaration	No related party
Date of assessment	5 November 2024
Date of certificate	5 November 2024
Type of assessment	RdSAP
